

## Overview

The SPC Milestone plugin has been developed by Vanderbilt and partners to provide you with an integration between Milestone system. This document provides an details on how to configure the plugin and however to configure the milestone system. Please note that the information is provided as accurate at time of writing and may not reflect the most update Milestone system.

The Milestone plugin is provided by Vanderbilt under licence the plugin can be installed in a Milestone Xprotect system. The plugin activates with a thirty-day free trail for a single SPC panel. When a plugin is purchased from Vanderbilt the plugin will support up to 20 SPC Panels.

Document ID: I-200272

Edition: 16/6/2017

## Contents

Revision History .....	4
Installation .....	5
Configuration of SPC .....	5
Management Client.....	8
Smart Client integration.....	10
Appendix.....	10
Panel.....	10
Customizations .....	15
Languages .....	15
Event Groups & Event Types .....	15
Events .....	15
States.....	15
Texts.....	15
Icons .....	16
Simulation Mode .....	18

# Contents

The information contained in this document is to the best of knowledge, true and accurate. Whilst every effort has been made to ensure the accuracy, the document may be subject to errors or omissions.

# Revision History

Rev	Date	Remarks
0.1	2017-6-16	Initial draft
0.2	2018-2-5	Updated To version 2
0.3	2018-05-17	Updated to Version 3 Changes in icons for zone open/close, area actions & rule actions Changes in icons for doors



milestone

## Installation

1. Download the Milestone plugin from Vanderbilt server.
2. Extract the installation package to the following folder (\*):  
C:\Program Files\Milestone\MIPPlugins

This is needed on the server running the Milestone Event Server and all machines running the management client.  
(\* ) this is the default folder, and can be different based on your Milestone installation settings.

## Configuration of SPC

The SPC panel must be configured to communicate with the Milestone system. The SPC creates a connection to the milestone plugin in order to communicate status and command information.

To configure all this, an ATS needs to be added in the 'FlexC' configuration tab.

*For more information on FlexC please see*

<https://youtu.be/f0jklbWfjlc>

First, an ATS must be configured:

Communications FlexC® Reporting PC Tools  
 FlexC ATS Event Profiles Command Profile FlexC Help

**ATS Configuration**

**Configured ATS**

Edit	Delete	Export ATS	ID	ATS Name	ATS Registration ID	ATP Count	Event / Command Profiles	ATS Polling Timeout	ATS Event Timeout	Generate FTC
			2	ATS 2	5654-22T9-X9R2-K884	1	- Event Profile 3 - Command Profile 3	90	300	Yes
			3	ATS 3	7474-T76K-62XS-G45T	1	- Event Profile 3 - Command Profile 3	90	300	Yes

**Add SPC Connect**  
 Add an ATS to the SPC Connect Server

**Add EN50136-1 ATS**  
 Add an EN50136-1:2012 single path ATS to the system.   
 Add an EN50136-1:2012 dual path ATS to the system.   
 Add an EN50136-1:2012 dual path and dual Server ATS to the system.

**Add Custom ATS**  
 Add a custom ATS to the system. Up to 10 ATPs may be added to the ATS.

**Import ATS**  
 Import an ATS to the system.

Communications FlexC® Reporting PC Tools  
 FlexC ATS Event Profiles Command Profile FlexC Help

**ATS Configuration [ATS 3]**

**Identification**

ATS Name  The name of the ATS  
 ATS Registration ID  The unique registration ID of the ATS allows the panel to be uniquely identified at the RCT.

**Event Sequence Table**

Edit	Delete	Move Up	Move Down	Seq No	Name	Communications Interface	ATP Category	Status	Active Polling Timeout (s)	Event Timeout (s)
		-	-	1	Primary ATP 1	Ethernet	Cat 5 [Ethernet]	OK	90	30

**ATS Profiles**

Event Profile  Select the Event Profile which defines how and which events are transmitted on this ATS  
 Command Profile  Select the Command Profile which defines the commands that are allowed on this ATS

**ATS Faults**

ATS Polling Timeout  Seconds An ATS Polling Timeout is raised if no Poll message has been successfully acknowledged on any ATP within this period. (0 = Auto Calculate)  
 ATS Event Timeout  Seconds An ATS Event Timeout is raised if an event has not been successfully acknowledged on any ATP within this period.  
 Generate FTC  Selects whether the system generates an FTC on an ATS Event Timeout or an ATS Polling Timeout  
 Re-queue Events  Select what happens to events after an ATS Timeout  
 Re-queue Event Delay  Seconds Delay after an ATS Event Timeout before the re-queued event is attempted again.  
 Re-queue Event Duration  Seconds Amount of time that the event will be re-queued before the event is deleted.

**Installation Details**

Installation Details  The following installation details are passed to the RCT to help the Operator at the RCT to identify the panel.

Then, an ATP must be added to the ATS:  
 Check the yellow fields:

ATP Configuration - FlexC RCT

Panel Identification

ATP Sequence No 1 Sequence number of ATP in the ATS configuration (1 is Primary, 2-10 is Backup)  
 ATP Unique ID 99 The Unique ID of the ATP so that it can be recognised by the RCT  
 ATP Name Primary ATP 1 The name of the ATP  
 SPT Account Code 1234 The number that uniquely defines the panel to the RCT (1-99999999, 0 = Auto assign)

RCT Identification

RCT ID 5678 The unique ID of the RCT (e.g. RCT ID of SPC ComXT) (1-99999999)  
 RCT URL or IP Address 192.168.1.200 URL or IP address of the RCT (e.g. SPC ComXT)  
 RCT TCP Port 52000 The TCP Port of the RCT (e.g. The TCP Port that SPC ComXT is listening on)

ATP Interface

Communications Interface Ethernet Interface used by ATP for communication  
 ATP Category Cat 5 [Ethernet] Select the The ATP category

Advanced

Advanced ATP Settings Advanced ATP Settings Advanced Settings should only be used by expert users who understand the impacts of wif

Back Save

Go to the advanced settings to configure the encryption key:

ATP Configuration - Advanced Settings

ATP Connections

Active ATP Connection Permanent: Stay Connected Select the ATP connection type when the ATP is the active ATP (operating as the primary communication path)  
 Non-Active ATP Connection Permanent: Stay Connected Select the ATP connection type when the ATP is not the active ATP (operating as a backup communication path)

Test Calls

Test call Mode (Non Active ATP) Test calls Disabled Select the mode for sending testcalls when the ATP is acting as the Non-Active ATP  
 Test call Mode (Active ATP) Test calls Disabled Select the mode for sending testcalls when the ATP is acting as the Active ATP

Encryption (256-bit AES with CBC)

Encryption Key Mode Fixed Encryption Select how the encryption key gets updated  
 Encryption key (64 hex digits) .....

ATP Profiles

Event Profile Use ATS Setting Select the Event Profile which defines how and which events are transmitted on this ATS  
 Command Profile Use ATS Setting Select the Command Profile which defines the commands that are allowed on this ATS

ATP Faults

ATP Monitoring Fault  Generate an ATP fault if the ATP monitoring fails or an Event fails to transmit on ATP  
 Event Timeout 30s The amount of time that the ATP will keep trying to transmit the event until the event fails on the ATP and is passed to the next ATP

Minimum Message Lengths


Poll Message 0 Bytes Minimum length of a Poll Message  
 Event Message 0 Bytes Minimum length of a Event and Testcall Messages  
 Other Message 0 Bytes Minimum length of connection and encryption key update messages

Back Save

# Management Client

Note: The configuration of the plugin is performed in the management client, smart client is used for map and controlling system. Please ensure plugin is in the correct folder

Configuration is done in the management client. The plugin sits in the 'Devices' tree.



A list of configured SPC Panels is shown. When selecting a panel, the details panes on the right is populated with the configuration of the panel as known in the system.

The panel detail pane shows the configuration details to be able to connect to the panel. The language chosen here will be used as language to get the alerts from the alarm panel, and also as language locale for the actions in the video client (currently not localizable yet)

All other tab-pages contain a list of the items with their properties. All of these properties are retrieved the panel when performing 'Reload Config' from the panel pane.

The button is only available when there is a confirmed connection to the SPC. Connection state is shown with the color or the button:

	State Unknown. Waiting for the event server to get the state
	Panel is offline
	Panel is online, but credentials weren't checked yet. If the panel stays in this state, probably the username or pwd are not OK
	Panel is online



When the field FlexC User equals 'SIMUL', then the system will be simulated. Otherwise, a real system communication is expected.

When in simulation mode, the configuration will be retrieved from the file 'configsimu.csv'.

The following items are retrieved from the SPC Panel:

## Areas

Area ID	Area Name	A Name	B Name	Related Camera
1	Area 112	Partset A	Partset B	
2	Area 2	Partset A	Partset B	
3	Area 3	Partset A	Partset B	
4	Area 4	Partset A	Partset B	

## Zones

Zone ID	Zone Name	Area ID	Zone Type	Related Camera
1	Front door	1: Area 112	1: Entry/Exit	
10	Door 1	1: Area 112	1: Entry/Exit	
2	Window 1	2: Area 2	0: Alarm	
3	Window 2	3: Area 3	0: Alarm	
4	PIR 1	4: Area 4	0: Alarm	

**Remark:** zones with as type 'unused' are not retrieved from the alarm panel.

## Outputs

Output ID	Output Name	Related Camera
1	PP500EM on/off	

**Remark:** Only Mapping Gates are retrieved; other output types cannot be retrieved.

## Doors

Door ID	Door Name	Related Camera
1	Door 1	

**Remark:** Other item types (eg expanders) cannot be retrieved from the SPC. Events on those items will be linked to the SPC panel item itself.

The only property that can be configured in the management client is the 'Related Camera'. When this is set, the camera image will be shown next to an event on this item.

# Smart Client integration

Each item of the SPC panel can be put on the map in the smart client.

Depending on the state, the icon and the available actions on the context menu can change.

Each item also has an 'operational state', which results in a circle around the item. This can have the following values:

Ok, Warning, Disabled, Error, OkActive

Actions are only available when the SPC is connected.

For an overview of the operation of the smart client please see the following video.

## Appendix

### Panel

#### Icon State

Icon changes on the connection state of the panel (see icons)

#### Actions

ID	Name	Condition
PANEL_ACT_SILENCE	Silence all Bells	
PANEL_RELOAD_STATE	Manually refresh the state. This is normally done automatically	
PANEL_ACT_RESET_ALERTS	Reset all alerts in the SPC	

#### Detailed States

ID	Name
PANEL.CONNECTIONSTATE	Current connection State
ALERT xxx	All alerts in the SPC are listed here, with the indication whether the alert is inhibited or isolated

Alerte 0.0.0.15 Controller Cabinet Tamper - Isolated

#### Operational State

State	Condition
Disabled	Panel is Disabled
Error	Alert Count > 0 or panel is not online
Ok	else

## Area

### Icon State

Icon changes on the state of the area (see icons)

### Actions

ID	Name	Condition
AREA_ACT_UNSET	Unset Area	Area is not unset
AREA_ACT_SET_A	Area Set Partially A	Area is unset or area is PartSet B
AREA_ACT_SET_B	Area Set Partially A	Area is unset or area is PartSet A
AREA_ACT_SET	Set Area	Area is not set

### Detailed States

ID	Name
AREA_MODE	Current mode of the area

### Operational State

State	Condition
Warning	If a zone in this area is in warning
Error	In a zone in this area is in error
OK	else

## Zone

### Icon State

Icon changes on the state of the zone (see icons)

### Actions

ID	Name	Condition
<b>ZONE_ACT_INHIBIT</b>	Inhibit zone	Inhibit allowed and status is not inhibited
<b>ZONE_ACT_DEINHIBIT</b>	De-Inhibit Zone	De-Inhibit allowed and status is inhibited
<b>ZONE_ACT_ISOLATE</b>	Isolate Zone	Isolate allowed and status is not isolated
<b>ZONE_ACT_DEISOLATE</b>	De-Isolate Zone	De-Isolate allowed and status is isolated
<b>ZONE_ACT_RESTORE</b>	Restore alarm	Restore Allowed and current status > 3

### Detailed States

ID	Name
<b>ZONE_STATUS</b>	Current status of the zone

### Operational State

State	Condition
<b>OK</b>	State = ZONE_STATUS_OK
<b>ERROR</b>	ZONE_STATUS_ALARM, ZONE_STATUS_TAMPER, ZONE_STATUS_TROUBLE, ZONE_STATUS_POST, ZONE_STATUS_MASKED
<b>Warning</b>	else

## Door

### Icon State

Icon changes on the state of the door (see icons)

### Actions

ID	Name	Condition
DOOR_ACT_NORMAL	Set Door Normal	DOOR_MODE_LOCKED or DOOR_MODE_UNLOCKED
DOOR_ACT_OPENPERM	Open door Permanently	DOOR_MODE_LOCKED or DOOR_MODE_NORMAL
DOOR_ACT_LOCK	Lock Door	DOOR_MODE_NORMAL or DOOR_MODE_UNLOCKED
DOOR_ACT_OPENTEMP	Open door Momentarily	DOOR_MODE_NORMAL

### Detailed States

ID	Name
DOOR_OPEN_STATE	DOOR_OPEN_STATE_CLOSED, DOOR_OPEN_STATE_OPEN
DOOR_STATUS	DOOR_STATUS_OK, DOOR_STATUS_OPEN_TOO_LONG, DOOR_STATUS_LEFT_OPEN, DOOR_STATUS_FORCED, DOOR_STATUS_TAMPER, DOOR_STATUS_OFFLINE,
DOOR_MODE	DOOR_MODE_NORMAL, DOOR_MODE_LOCKED, DOOR_MODE_UNLOCKED,


### Operational State

State	Condition
OK	DOOR_STATUS_OK
ERROR	DOOR_STATUS_OPEN_TOO_LONG, DOOR_STATUS_FORCED, DOOR_STATUS_TAMPER, DOOR_STATUS_OFFLINE
Warning	else

## Rules and actions

### Rules

SPC Events can be used as a trigger action. All defined events can be configured as trigger: you may also configure actions to take place on the SPC system.



## Customizations

A lot of things are configurable in the plugin. These settings are all in the file SPCMilestone.data. This file is actually a zip-file containing all necessary settings and icons. Most of the configurations are done the file called meta.csv.

## Languages

### Syntax:

```
language;{Language-id in the SPC};{Name of language};{Locale}
```

### Example:

```
language;0;English;en-US
```

### Usage:

This defines the languages shown in the panel-configuration screen.

## Event Groups & Event Types

This is used in the Milestone system to configure alarms.

### Syntax:

```
eventgroup;{text of group}
eventtype;{text of event type};{group for event type};{entity type}
```


### Example:

```
eventgroup;SPC.AREA.EVENTS
eventtype;SPC.AREA.EVENT_UNSET;SPC.AREA.EVENTS;AREA
```

### Usage:

The 'text of...' parts must appear in the text-section to get the real localized text.

Entity type is one of the following: AREA, PANEL, ZONE, DOOR



## Events

The translation of SPC events to Milestone events is via the 'eventtranslation' keyword

### Syntax:

```
eventtranslation;{entity type};{spc event};{event type}
```

### Example:

```
eventtranslation;AREA;3505;SPC.AREA.EVENT_UNSET
```

## States

The translation of SPC events to Milestone states is via the 'statetranslation' keyword

### Syntax:

```
statetranslation;{entity type};{spc event};{state text};{state value}
```

### Example:

```
statetranslation;AREA;3505;AREA_MODE;0
```

## Texts

Definition and localization of the different texts is done via the 'text' keyword

### Syntax:

```
text;{text id};{locale};{text}
```

**Example:**

```
text;SPC.AREA.EVENTS;en-US;Area Events
text;SPC.AREA.EVENTS;fr-FR;Evènements du secteur
text;SPC.AREA.EVENT_UNSET;fr-FR;MHS secteur
text;SPC.AREA.EVENT_UNSET;en-US;Area Unset
```

**Icons**

Icons are fully customizable. The following table shows the rules to fetch the icons:

Entity	Purpose	File Name
<b>Panel</b>	Single	SPCPanel.ico
<b>Panel</b>	Multiple	SPCPanels.ico
<b>Panel</b>	State	SPCPanel-{state}.ico  State is one of the following: 0: PANEL_STATUS_OK 1: PANEL_STATUS_ENGINEERING 2: PANEL_STATUS_OFFLINE 3: PANEL_STATUS_OFFLINE_CONF
<b>Area</b>	Single	SPCArea.ico
<b>Area</b>	Multiple	SPCAreas.ico
<b>Area</b>	State	SPCArea-{state}.ico  State corresponds to the current mode of the system
<b>Zone</b>	Single	SPCZone.ico
<b>Zone</b>	Multiple	SPCZones.ico
<b>Zone</b>	State	SPCZone-{type}-{state}.ico  Type corresponds to the Type of the zone  State corresponds to the current 'STATUS' of the zone
<b>Door</b>	Single	SPCDoor.ico
<b>Door</b>	Multiple	SPCDoors.ico
<b>Door</b>	State	SPCDoor-{state}.ico  State corresponds to current 'STATUS' of the door
<b>Output</b>	Single	SPCOutput.ico
<b>Output</b>	Multiple	SPCOutputs.ico
<b>Output</b>	State	SPCOutput-{state}.ico  State corresponds to current 'STATE' of the Mapping Gate



**Remarks:**

Each action can have an icon that will be shown in the menu-list. See Smart Client Integration for the ID's of the actions.

All icon files must contain the sizes 8x8 until 64x64.

## Simulation Mode

The plugin can run in simulation mode. In this mode, no actual communication is performed. Configuration is fetched from the file configsimu.csv.

Events can be sent via the tab 'Simulate' in the management client. This window permits to simulate an event on the panel. An events consists of two parts: the event code and the related item. This must be separated by a semicolon as shown below.

---